

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	Schneider Electric Industries SAS
Address	Zone Industrielle 3, L'ISLE D'ESPAGNAC, 16340, France
Place of Production	Schneider Electric a.s. Cizovska 447, Pisek, 397 01, Czech Republic
Place of Production	PT. Schneider Electric Manufacturing Batam Batamindo Industrial Park, Block 4 & 208, Muka Kuning, Batam Island, 29433, Indonesia
Place of Production	Schneider Electric Industries SAS Zone Industrielle 3, L'ISLE D'ESPAGNAC, 16340, France
Type	Switches - Control
Description	Control and signaling units Harmony XB4 metal: XB4BA, XB4BC, XB4BD, XB4BG, XB4BJ, XB4BK, XB4BL, XB4BP, XB4BS, XB4BT, XB4BV, XB4BW, XB4FA, XB4FD, XB4FG, XB4FJ, XB4FK, XB4FL, XB4FV, XB4FW, XD4PA Harmony XB5 plastic: XB5AA, XB5AC, XB5AD, XB5AG, XB5AJ, XB5AK, XB5AL, XB5AP, XB5AS, XB5AT, XB5AV, XB5AW,



Pawan Borate

Specialist Electrical & Control to Lloyd's Register Marine and Offshore India LLP
A member of the Lloyd's Register group

Units 1702-1704, 17th Floor (Level-13), Building Q2, Aurum Q Parc; Gen 4/1 TTC, Thane-Belapur Road, Ghansoli, Navi Mumbai, 400710, India

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Type Approval Certificate

XB5EV,
XB5FA, XB5FD, XB5FG, XB5FJ, XB5FK, XB5FL, XB5FV, XB5FW,
XB5KS,
XD5PA

Trade Name

XB4, XB5

Application

Marine, Offshore and Industrial applications for use in environmental categories ENV1, ENV2, ENV3 and ENV5 ⁽¹⁾, as defined in Lloyd's Register Type Approval System, Test Specification Number 1 –December 2021.
(1) not valid for XB5KS

Specified Standard

IEC 60947-5-1: 2024
IEC 60947-5-5: 2026
IACS UR E10 Rev. 10

Ratings

Rated voltage:
XB4B/F, XB5A/F: up to 600 V
XD4P, XD5P: up to 250 V
Ingress protection
IP66 (when installed)
IP20 (rear side)

Additional Tests

Ingress protection IP66 (when installed)

Other Conditions

The buzzer XB5KS shall not be installed on the bridge as the sound pressure level exceeds the limit specified in IMO Resolution A.1021(26) Code on Alerts and Indicators.

Type Approval does not eliminate the need (as required by LR Rules) the requirements for further review or for the product to be further inspected and/or surveyed to be installed in ships classed or intended to be classed with LR



Type Approval Certificate

If the specified standards are amended during the validity of this certificate, the product is to be re-approved prior to it being supplied to vessels to which the amended standards apply.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Marine and Offshore India LLP of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR2333559TA

The Design Appraisal Document TSO-26-053518-E-01 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Units 1702-1704, 17th Floor (Level-13), Building
Q2, Aurum Q Parc; Gen 4/1 TTC, Thane-Belapur
Road, Ghansoli, Navi Mumbai, 400710, India

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.