



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2008010305268220

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

SCHNEIDER ELECTRIC INDUSTRIES SA (V054246)
52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

PRODUCT NAME, MODEL AND SPECIFICATION

Safety Limit Switch

XCSA, XCSB, XCSC: Ui: 500V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:240V/3A;
DC-13:Ue/Ie:250V/0.27A; IP67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.25,2020

Valid until: Sep.24,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0372778



产品认证证书

证书编号: CQC2008010305268220

申请人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路669号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

SCHNEIDER ELECTRIC INDUSTRIES SA(V054246)
52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

产品名称和系列、规格、型号

安全限位开关

XCSA, XCSB, XCSC: Ui: 500V; Uimp: 6kV; Ith: 10A; AC-15: Ue/Ie: 240V/3A;
DC-13: Ue/Ie: 250V/0.27A; IP67; 详细型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年08月25日 有效期至: 2024年09月24日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0372778



产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2008010305268220

纸号: 372778

型号解释:

$\frac{XCS}{I}$	$\frac{A}{II}$	$\frac{5}{III}$	$\frac{0}{IV}$	$\frac{3}{V}$
I-	产品型号 XCS 安全限位开关			
II-	联锁形式 A - 无锁 B - 有锁, 按钮解锁 C - 有锁, 钥匙解锁			
III-	触头形式 5 - 1 NC + 2 NO 7 - 2 NC + 1 NO 8 - 3 NC			
IV-	LED 0 - 无 LED 1 - 带 1 个 LED 24-48 V ac/dc 2 - 带 1 个 LED 110-240 V ac			
V-	接口形式 1 - 13 号欧洲电缆密封管螺纹孔 2 - ISO 电缆密封管螺纹孔 3 - 1/2 in. NPT 螺纹孔			

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2008010305268220

纸号: 372778

<u>XCS</u> I	<u>A</u> II	<u>5</u> III	<u>0</u> IV	<u>3</u> V
I-	Product type XCS safety limit switch			
II-	Type of interlocking A - Without locking of key B - with locking of key, unlocking by pushbutton C - with locking of key, unlocking by key operated lock			
III-	Type of contact block 5 - 1 NC + 2 NO 7 - 2 NC + 1 NO 8 - 3 NC			
IV-	LED 0 - Without 1 - With one LED 24-48 V ac/dc 2 - With one LED 110-240 V ac			
V-	Type of entry 1 - Threaded hole for Type 13 European cable gland 2 - Threaded hole for ISO cable gland 3 - 1/2 in. NPT threaded hole			

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>