



# Certificate of Compliance

**Certificate:** 2406135

**Master Contract:** 158337 (LL 89066)

**Project:** 70187533

**Date Issued:** 2018-06-12

**Issued to:** Schneider Electric USA, Inc. Square D  
Distribution Equipment Business  
1601 Mercer Rd  
Lexington, Kentucky 40511  
USA  
**Attention:** Manuel Salinas

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Ronald Tateishi  
Ronald Tateishi

## PRODUCTS

CLASS 4621 01 – PANELBOARDS - Panelboards and Enclosed Panelboards

Enclosed panelboards with main lugs or main circuit breaker, Type CHOM, Series 01 to 04, 1-ph, 2- or 3-wire, 120/240V ac max, 225A max for main lugs, 200A max for main circuit breaker, 42 branch poles max, 84 circuits max.

## APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 29 - Panelboards and Enclosed Panelboards  
CSA Standard C22.2 No. 94.2 - Enclosures for Electrical Equipment, Environmental Considerations



## *Supplement to Certificate of Compliance*

**Certificate:** 2406135

**Master Contract:** 158337 (LL 89066)

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>
70187533	2018-06-12	Addition of an alternate wire connector.
70138495	2017-05-24	Addition of the manufacturer (Sabic Innovative Plastics) of the plastic closing cap used on the conduit hub opening.
70125448	2017-03-27	Addition of alternate neutral bars.
70014828	2014-11-03	Update to Report 2406135 to cover plug on neutral construction
2653498	2013-08-26	Addition of the Catalogue No. CHOM3060L125GC panelboard.
2587139	2012-12-19	Addition of an alternate material (Asahi Kasei Chemicals Corp, Xyron 540V) for the distribution and neutral mounting bases.
2406135	2011-03-10	Original Certification.